

CERTIFICATE FI/41442/M1

Our Ref. HEL-CERT220701157-02



Product	Socket-outlet
Type	15002
Trademark	ELKO
Certificate Holder	Elko AS Sandstuveien 68, N-0680, Oslo, Norway
Technical information	16 A/2.5 A, 250 V~
Other information	Socket outlets for flat plugs, Class II. Standard Sheet XVIa. Thermoplastic, flush mounting and surface mounting, 3-gang, with shutters and screw terminals, IP21 for surface variant. IP20 for flush variant. IP21 for flush variant when installed in declared surface box, Plus or RS or One design, all colors.
The product is certified according to the following standard(s)	IEC 60884-1:2002 + A1:2006 + A2:2013 SFS 5610:2015 + A11:2016


Validity This certificate is valid until 2027-07-22 provided that the Conditions for FI certification are met. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

Date of issue 2024-01-16

SGS Fimko Ltd

Signature


Jonas Leinonen
Certification Manager



Manufacturer

Elko AS
Sandstuveien 68, N-0680, Oslo, Norway

Manufacturing site

AS M & P Nurst
Ümarmäe 3, Kärkla 92414, Hiiumaa, Estonia

Additional information

The products have certificate no. P22226274/A1 issued by Nemko Group in accordance with the Nordic Certification Service system.

This certificate replaces previous certificate FI/41442, dated 2022-07-22, due to addition of new design.

IP21 for flush mounted socket-outlet when installed in declared surface boxes as follows:

- Plus:
 - 1-gang box L3429/L991 (40mm high),
 - 2-gang box L3478/L992 (40mm high),
 - 3-gang box L3480/L993 (40mm high)
- RS:
 - 1-gang box L889/L991 (33mm high),
 - 2-gang box L888/L992 (33mm high),
 - 3-gang box L890/L993 (33mm high),
 - 4-gang box L3542/L3543 (33mm high)
- One:
 - 1-gang box PKR1049402/PKR1049502 (45mm high),
 - 2-gang box PKR1049602/PKR1049802 (45mm high),
 - 3-gang box PKR1049902/PKR1050002 (45mm high)

As shown in the Test Report(s) No(s): 467913, REP016958