



Reference No. SE-S-2400452

## Socket-outlet with electronic switch

**Type designation:** ESC5011

**Certificate holder:** ELKO A/S

Sandstuveien 68 0680 Oslo

NORWAY

The product complies with the standard(s):

EN 60669-2-1:2004+A1+A12

EN 60669-2-5:2016

EN 60669-1:2018 SFS 5610:2015+A11 NEK 502:2016 +A1 SS 428 08 34:2013+T1 IEC 60884-1:2002+A1+A2

Date of expiry: 14 May, 2029

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification Place: Kista - Stockholm

Signed: Date: 14 May, 2024

Anneli Averland Johansson

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. This certificate is not issued under accreditation, by a non-approved body.

Intertek Semko AB Page 1 of 2 ÅSE



## **APPENDIX:**

Reference No. SE-S-2400452

**Technical Data:** 

Trademark

Type designation ESC5011
Rated voltage (V) 230V~
Rated current (A) 16A
Frequency (Hz) 50 Hz
IP-Class IP20
Standard sheet III

**ELKO** 

Test Report 277196-TL3-2, 308502-TL3-1, 2402674ST0-001

Product information Socket outlet with incorporated electronic switch for flush mounting.

With screw terminals. μ- gap disconnection.

For loads: Incandescent lamps 2000W. Electronic transformer 2000VA.

Iron core transformers 1500VA. LED lamps 100W (125,μF),

Resistive loads 3680W, Fluorescent load 6AX max 70  $\mu$ F, Inductive load: 16A

 $\cos \phi = 0.6$ , Motor load: 1600VA, max 7A.

Manufacturing Sites: SIA Lexel Fabrika

Krustpils street 35A

LV-1073 Riga LATVIA

This certificate is based on CB Certificate with ref. No. DE1-67925/M1 dated 2024-03-27, issued by VDE.

Certification Body: Intertek Semko AB, Product Certification Place: Kista - Stockholm

**Signed:** Date: 14 May, 2024

Anneli Averland Johansson

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement, Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. This certificate is not issued under accreditation, by a non-approved body.

Intertek Semko AB Page 2 of 2 ÅSE